

Addendum #2

June 23, 2015

The following information supplements and/or supersedes the bid documents. This Addendum forms part of the contract documents and is to be read, interpreted, and co-ordinated with all other parts. The cost of all contained herein is to be included in the contract sum. The following revisions supersede the information contained in the original drawings issued for the above-named project to the extent referenced and shall become a part thereof. Acknowledge receipt of this Addendum by inserting its number and date on the Tender Form. Failure to do so may subject the Bidder to disqualification.

.1 **ELECTRICAL:**

1. **Smoke Alarms:**

1. In accordance with the January 1, 2015 amendments to Div B Sentence 9.10.19.1.(2) of the Ontario Building Code 2012, smoke alarms shall have a visual signaling component.

.2 **ARCHITECTURAL DRAWINGS:**

1. **Drawings of Addendum #1:**

1. Drawings that were amended by Addendum #1 have been included in the original 24" x 36" set of Documents, issued for Tender and Construction. These drawings replaced the original drawings and include the following:
 - Drawing A2.1A
 - Drawing A2.1B
 - Drawing A2.1D, and
 - S-2.

End of Addendum #2